



Superstition Fire & Medical District

Serving the Communities of Apache Junction and Gold Canyon since 1955

Phone | (480) 982-4440

Website | sfmd.az.gov

FOOD TRUCK / FOOD VENDOR FIRE & LIFE SAFETY REQUIREMENTS

- A **minimum Classification of 2A:10 BC Fire Extinguisher** is required for all food vendors, and must be accessible at all times.
 - Provide required annual service & tag from licensed contractor.
- A **K-Classification Fire Extinguisher** is required for all **grease laden (frying) activity.** (This does not replace the required 2A:10 BC Fire Extinguisher, it's in addition to)
 - Provide annual service & tag from licensed contractor.
- **Cooking Hood Systems** must be maintained with **Bi-Annual service & cleaning.** Service Tags are required to be present and legible.
- **ALL compressed gas cylinders, including LPG tanks and CO2 tanks,** are required to be secured at all times.
- **Electrical breaker panels** must be accessible, have breaker schedules, and must have blank covers for unused breakers.

Thank you for your cooperation. Please contact my office with any questions you may have at (480) 982-4440, Ext. 104.

Tina Gerola,

Tina Gerola

Deputy Fire Marshal

Administration Office
565 North Idaho Road
Apache Junction, AZ 85119

Regional Training Center
3700 East 16th Avenue
Apache Junction, AZ 85119

Fleet Services
1455 East 18th Avenue
Apache Junction, AZ 85119